

# Preliminary Assessment Report

## Project 3016574, 1812 BOREN AVE

---

**Assessment Completed:** 12/19/2013

**Project Description:** New building with office, residential (approximately 400 units) and retail uses. Below grade parking and on-grade loading accessed from existing alley. Existing building located at 1812 Boren Avenue to be demolished

**Primary Applicant:** [Corinne Kerr](#)

This report lists the results of a preliminary assessment of your project requirements by various city departments. It's based on the project characteristics described on your site plan and preliminary application form. If your project required a pre-application site visit (PASV), the results of that site visit are also included. The goal of this report is to help you create a complete submittal package and reduce the need for corrections once your application has been submitted.

### Next Steps

1. Review the requirements in this report and contact the staff members listed below with questions.
2. If a street improvement plan is required, develop and submit it to the Seattle Department of Transportation (SDOT). **The Department of Planning and Development (DPD) will not accept your permit application until your street improvement plan is approved as 60% complete by SDOT. See [SDOT Client Assistance Memo 2213](#) for guidance about the 60% complete approval process.**
3. Schedule an appointment for permit application intake with DPD. **Please bring a copy of this report to your intake appointment.**

### Questions About This Report

If you have questions about the information in this report, contact the appropriate city staff member for each section.

#### DPD Drainage Requirements

Joseph P Berentsen, (206) 684-8613, [Joe.Berentsen@seattle.gov](mailto:Joe.Berentsen@seattle.gov)

#### DPD Land Use Requirements

Christopher Amba Ndifon, (206) 233-7938, [christopher.ndifon@seattle.gov](mailto:christopher.ndifon@seattle.gov)

#### DPD Preapplication Site Visit Requirements

Douglas Thresher, (206) 233-3875, [Douglas.Thresher@seattle.gov](mailto:Douglas.Thresher@seattle.gov)

#### Seattle City Light Requirements

Ray Ramos, (206) 615-1193, [ray.ramos@seattle.gov](mailto:ray.ramos@seattle.gov)

#### Seattle Department of Transportation Requirements

Yohannes Minas, (206) 733-9044, [yohannes.minas@seattle.gov](mailto:yohannes.minas@seattle.gov)

#### Seattle Public Utilities Requirements

Jennyfer Jacobsen, (206) 684-8766, [JacobsJS@seattle.gov](mailto:JacobsJS@seattle.gov)

#### Water Availability

P Kimani, (206) 684-5975, [Karen.Younge@Seattle.Gov](mailto:Karen.Younge@Seattle.Gov)

## Other Resources

- General questions about the permit process: Contact the DPD Applicant Services Center (ASC) at 206-684-8850.
- User-friendly guides to city permitting processes: [DPD](#) and [SDOT](#).
- [Detailed zoning information](#).
- Visit our [permit type pages](#) for step-by-step instructions and forms for preparing your application and plans for review.

## Requirements

### **DPD Drainage Requirements**

The following requirements are based on the current stormwater and side sewer codes.

#### **Existing Public Drainage Infrastructure**

Combined sewer main location: Boren Ave.

Combined sewer main size: 8" and 12" Diameter

#### **Drainage**

The drainage point of discharge (SMC 22.805.020) is located at: Combined sewer.

#### **Flow Control Compliance**

All new, replaced, and disturbed topsoil shall be amended with organic matter per rules promulgated by the Director prior to completion of the project to improve onsite management of drainage water flow and water quality per SMC 22.805.020.E. A completed [Construction Stormwater Control and Soil Amendment Standard Plan](#) is required.

Parcel-based projects with 7,000 square feet or more of land disturbing activity or 2,000 square feet or more of new plus replaced impervious surface must implement green stormwater infrastructure (bioretention cells, green roofs, permeable pavement, rainwater harvesting, etc.) to infiltrate, disperse, and retain drainage water onsite to the maximum extent feasible per SMC 22.805.020.F. and [Director's Rule 15-2012](#).

Flow control standards must be first met by utilizing green stormwater infrastructure to the maximum extent feasible. Additional flow control measures shall be installed if the flow control standard cannot be met solely using green stormwater infrastructure. Refer to [DR 17-2009](#). Submit a [Green Stormwater Requirement Calculator](#) along with additional flow control documentation.

For more information see: <http://www.seattle.gov/dpd/codesrules/codes/stormwater/default.htm>

This project site discharges to a **Public Combined Sewer** (SMC 805.050.A.5). Based upon the information provided on the Preliminary Application Form pertaining to land disturbing activity and existing and proposed impervious surfacing, this project shall **provide flow control meeting the Peak Flow Control Standard per SMC 22.805.080.B.4.**

The post-development peak flow with a 4% annual probability (25-year recurrence flow) shall not exceed 0.4 cubic feet per second per acre. Additionally, the peak flow with a 50% annual probability (2-year recurrence flow) shall not exceed 0.15 cubic feet per second per acre.

Projects with less than 10,000 sf new plus replaced impervious surface can use the [Pre-Sized Flow Control Calculator](#) in lieu of continuous modeling.

#### **Water Quality**

No requirements

#### **Wastewater**

All homeowners and building owners in King County's service area whose home or building was newly connected to the King County sewer system on or after Feb. 1, 1990 must pay a [King County Capacity Charge](#).

#### **Permanent and Temporary Dewatering**

Per SMC 21.16.110, the proposed project requires a separate side sewer permit for temporary dewatering based on the following: excavation greater than 12 feet deep.

The footing drain (if part of building plan) point of discharge ([DPD DR 4-2011](#)) is located at the following: Combined system.

## **DPD Land Use Code Requirements**

### **Street Requirements**

Based on the scope of the proposed project, the following street improvements are required per Chapter 23.53 of the Seattle Municipal Code. Please review Right-of-Way Improvements Manual for design criteria (<http://www.seattle.gov/transportation/rowmanual/manual/>). Show required street improvements on your "enhanced site plan" at DPD permit application intake. If an SDOT Street Improvement Plan (SIP) is required, please list SDOT project number and SDOT contact name on the enhanced site plan. Street Improvement Plans must be accepted by SDOT prior to DPD permit application intake.

#### **STEWART ST**

Street trees shall be provided in the planting strip according to Seattle Department of Transportation Tree Planting Standards. Contact SDOT Urban Forestry (for residential projects: (206) 684-TREE; for all others: (206) 684-5693), to determine species of tree and standards of planting. Please add a note to the site plan showing size, location and species of tree to be planted.  
<http://www.seattle.gov/transportation/treeplanting.htm>.

#### **BOREN AVE**

Street trees shall be provided in the planting strip according to Seattle Department of Transportation Tree Planting Standards. Contact SDOT Urban Forestry (for residential projects: (206) 684-TREE; for all others: (206) 684-5693), to determine species of tree and standards of planting. Please add a note to the site plan showing size, location and species of tree to be planted.  
<http://www.seattle.gov/transportation/treeplanting.htm>.

#### **HOWELL ST**

Street trees shall be provided in the planting strip according to Seattle Department of Transportation Tree Planting Standards. Contact SDOT Urban Forestry (for residential projects: (206) 684-TREE; for all others: (206) 684-5693), to determine species of tree and standards of planting. Please add a note to the site plan showing size, location and species of tree to be planted.  
<http://www.seattle.gov/transportation/treeplanting.htm>.

### **Alley Requirements**

#### **Alley on North side**

Design structure to accommodate grade of future alley improvements. See <http://www.seattle.gov/transportation/gradesheetintro.htm>.

A 2-foot foot dedication is required. Refer to SDOT CAM 2203. Please see [http://www.seattle.gov/transportation/stuse\\_docs.htm](http://www.seattle.gov/transportation/stuse_docs.htm).

### **Land Use**

An arborist report may be required. See CAM 242 for more detail.

### **Notes to Applicant**

Planting of street trees are required Per SMC 23.47A.016.B.

## **Pre-Application Site Visit (PASV) Requirements**

PASV report requirements may be subject to additions, changes, or modifications by the department. The purpose of the report is to alert the applicant that there may be unusual or complex site conditions that trigger requirements from the department regarding this project. **The applicant is responsible for providing all required documents at the intake appointment.** If you have questions about this report or the PASV process, please contact the DPD Site Development Team at (206) 684-8860.

**Note:** Any project application associated with the development site can utilize the results from this PASV if the application is accepted by DPD within 24 months of the above inspection date. After 24 months, the applicant must apply for another PASV. No extensions will be granted.

### **ECA Mapping Unit and Type**

Non-ECA

### **Earth Disturbance**

If excavation has the potential to encroach on adjacent property in order to facilitate construction activity, please provide documentation of consent from the adjacent property owner. Show area of proposed encroachment on the submitted drawings and detailed cross-sections.

If temporary cuts greater than 1h:1v will be required in order to facilitate construction activity, please provide a geotechnical engineer's verification that soil conditions allow cuts to stand unsupported. Include detailed cross sections.

Please show all existing and proposed retaining walls/rockeries and the exposed height.

If shoring will be required, please provide submittals by geotechnical and structural engineers and show the proposed system on the submitted drawings. Include detailed cross sections.

## **Existing ROW Conditions**

### **STEWART ST**

Street conditions:

Asphalt paving

Curb conditions:

Curb adjacent to site

Concrete

Approximate curb height: 4" inches

A storm inlet is located <350 ft from the site and prior to crossing a public right of way.

It appears that drainage from that discharge point will remain in the gutter line all the way to the nearest inlet structure, but this assessment is preliminary and it is the responsibility of the applicant to meet all relevant SW code requirements.

### **BOREN AVE**

Street conditions:

Asphalt paving

Curb conditions:

Curb adjacent to site

Concrete

Approximate curb height: 3" inches

A storm inlet is located <350 ft from the site and prior to crossing a public right of way.

It appears that drainage from that discharge point will remain in the gutter line all the way to the nearest inlet structure, but this assessment is preliminary and it is the responsibility of the applicant to meet all relevant SW code requirements.

### **HOWELL ST**

Street conditions:

Asphalt paving

Curb conditions:

Curb adjacent to site

Concrete

Approximate curb height: 3" inches

A storm inlet is located <350 ft from the site and prior to crossing a public right of way.

It appears that drainage from that discharge point will remain in the gutter line all the way to the nearest inlet structure, but this assessment is preliminary and it is the responsibility of the applicant to meet all relevant SW code requirements.

### **Alley on North side**

Concrete paving

V-shaped cross-section

## **Potential Impacts to Seattle Parks Property**

No parks property in vicinity

## **Tree Protection**

Existing trees appear to be shown accurately on the site plan

## **Construction Stormwater Control**

All projects with earth disturbance, regardless of size, require temporary and permanent stormwater control in accordance with the Construction Stormwater Control (CSC) Technical Requirements Manual ([DR 16-2009, Volume 2](#)).

**Show the following on the [Construction Stormwater Control and Soil Amendment Standard Plan](#):**

Place compost socks, compost berms, filter fabric fencing, straw bales, straw wattles, or other approved perimeter control BMPs to eliminate construction stormwater runoff.

Show the location of a stabilized construction access to the site; show methods to eliminate uncontrolled conveyance of mud and dirt into the right of way (ROW).

Place silt-trapping inserts in receiving catch basins located within 10 feet of construction entrance.

Cover bare soil with compost blankets, straw, mulch, matting, or other approved equal to control construction stormwater runoff.

Cover stockpiles and bare slopes with compost blankets, tarps, matting or other approved equal to control construction stormwater runoff.

A First Ground Disturbance inspection is required before any ground disturbance related to this permit, including demolition, tree cutting, clearing, grubbing, and grading. After your permit is issued, schedule an inspection by calling (206) 684-8900 or [online](http://web1.seattle.gov/DPD/InspectionRequest/default.aspx) at <http://web1.seattle.gov/DPD/InspectionRequest/default.aspx>.

## **Seattle City Light Requirements**

### **Street/Alley Requirements**

#### **STEWART ST**

Underground electrical facilities/conductors require separation from other utilities. Review SCL Construction Guideline U2-10/NDK-50, Electrical Conduit and Facilities in the Public Rights of Way (<http://www.seattle.gov/Light/engstd/>). Before digging, contact the Utilities Underground Location Center ("one-call") at (800) 424-5555 two business days in advance to locate and mark underground utilities, per state law (RCW 19.122). There are underground high voltage lines and electrical facilities along Stewart St.

#### **BOREN AVE**

Underground electrical facilities/conductors require separation from other utilities. Review SCL Construction Guideline U2-10/NDK-50, Electrical Conduit and Facilities in the Public Rights of Way (<http://www.seattle.gov/Light/engstd/>). Before digging, contact the Utilities Underground Location Center ("one-call") at (800) 424-5555 two business days in advance to locate and mark underground utilities, per state law (RCW 19.122). There are underground electrical lines and facilities for streetlighting along Boren Ave.

#### **HOWELL ST**

Underground electrical facilities/conductors require separation from other utilities. Review SCL Construction Guideline U2-10/NDK-50, Electrical Conduit and Facilities in the Public Rights of Way (<http://www.seattle.gov/Light/engstd/>). Before digging, contact the Utilities Underground Location Center ("one-call") at (800) 424-5555 two business days in advance to locate and mark underground utilities, per state law (RCW 19.122). There are underground high voltage lines and electrical facilities along Howell St.

#### **Alley on North side**

Underground electrical facilities/conductors require separation from other utilities. Review SCL Construction Guideline U2-10/NDK-50, Electrical Conduit and Facilities in the Public Rights of Way (<http://www.seattle.gov/Light/engstd/>). Before digging, contact the Utilities Underground Location Center ("one-call") at (800) 424-5555 two business days in advance to locate and mark underground utilities, per state law (RCW 19.122). There are underground high voltage lines and electrical facilities along the alley.

Your project is located in a Seattle City Light Network area. Based on our assessment of the size of your project, you may need transformers on your private property for power service to your building. This can be done with vaults inside the building or below grade vaults exterior to the building. Include these facilities for your project power needs in your building plans. SCL has access, clearance, size and location requirements for vaults or pads. Some transformers require long lead times to obtain. Contact SCL well in advance to provide electrical service service size and voltage details.

### **Conservation**

Energy Smart Services. Seattle City Light offers energy conservation grants for large new construction projects designed to exceed the energy efficiency requirements of the Seattle Energy Code. Contact Seattle City Light early in the design process to receive free energy analyses and funding estimates by utility staff, and funding for whole-building energy analysis by private sector consultants. The program is win-win. Tenants and buyers are attracted by reduced operating costs, while the project developers benefit from additional LEED points and grants to help offset increases in construction costs. The utility meets load growth through an investment that is less expensive than building new generating facilities. Designers are better able to promote the economics of cutting edge designs. Call (206) 684-3254 today to take advantage of this opportunity.

### **Notes to Applicant**

For new service, an Application for Electrical Service must be submitted to Seattle City Light. Please contact the Electrical Service Representative for your area several months before new service is required to determine your electric service design, service location and what kind of service is available at the building site. The Electrical Service Representative should also be contacted to coordinate electrical disconnections prior to demolition and temporary power for construction. Your Electrical Service Representative is: Richard Ohashi,

206-386-1674, richard.ohashi@seattle.gov. Be advised that it is the applicant's responsibility to seek guidance from SCL. Failure to contact SCL at your earliest convenience could severely impact your project's scope, schedule and budget. This responsibility rests solely with the applicant.

## **SDOT Requirements**

The City of Seattle's Right-of-Way Improvements Manual (ROWIM) and SDOT's Street & Sidewalk Pavement Opening and Restoration (PORR) Director's Rule 2004-02 may be accessed from SDOT's Street Use website at: [http://www.seattle.gov/transportation/stuse\\_docs.htm](http://www.seattle.gov/transportation/stuse_docs.htm). Whenever possible, specific reference notation for these two design documents is noted next to the design characteristics below. Be advised that these specific section and chapter references are provided as preliminary guidance only and are not comprehensive in scope.

### **SDOT Permitting Information**

Initial Review Deposit: \$2,500

SDOT Plan Requirements: Engineered plan

SDOT Permit Requirements: Group 3: Street Use Major (Type 45). A 60% complete street improvement plan (SIP) must be approved by SDOT prior to your DPD construction intake appointment. SIP Design Guidance is required for 60% complete SIP approval; apply early. Please visit SDOT's Street Use website at: [http://www.seattle.gov/transportation/stuse\\_sip.htm](http://www.seattle.gov/transportation/stuse_sip.htm) to obtain SDOT Client Assistance Memos (CAMs) and application materials to assist in developing your street improvement plan (SIP).

### **Street Improvement Requirements** **STEWART ST**

Tree protection: Removal of trees in the public right-of-way (ROW) is prohibited. Projects must be designed to accommodate existing trees in the ROW. Exceptions to this policy require review and approval by SDOT Urban Forestry. For residential projects, call (206) 684-TREE; for all other projects, call (206) 684-5693. Contact SDOT Urban Forestry immediately if you are proposing to remove street trees. If an exception from street tree removal is not granted, the project will need to be redesigned to preserve street trees.

Tree planting. See Seattle Right of Way Improvements Manual (ROWIM) and City of Seattle Standard Plans 030, 100 and 424. Contact SDOT Urban Forestry for residential projects at (206) 684-TREE; for all others at (206) 684-5693 for approval of species and placement.

New/Replacement Curb: See Seattle Right of Way Improvements Manual (ROWIM) and the City of Seattle Standard Plan 410.

### **BOREN AVE**

Tree protection: Removal of trees in the public right-of-way (ROW) is prohibited. Projects must be designed to accommodate existing trees in the ROW. Exceptions to this policy require review and approval by SDOT Urban Forestry. For residential projects, call (206) 684-TREE; for all other projects, call (206) 684-5693. Contact SDOT Urban Forestry immediately if you are proposing to remove street trees. If an exception from street tree removal is not granted, the project will need to be redesigned to preserve street trees.

Tree planting. See Seattle Right of Way Improvements Manual (ROWIM) and City of Seattle Standard Plans 030, 100 and 424. Contact SDOT Urban Forestry for residential projects at (206) 684-TREE; for all others at (206) 684-5693 for approval of species and placement.

New/Replacement Curb: See Seattle Right of Way Improvements Manual (ROWIM) and the City of Seattle Standard Plan 410.

### **HOWELL ST**

Tree planting. See Seattle Right of Way Improvements Manual (ROWIM) and City of Seattle Standard Plans 030, 100 and 424. Contact SDOT Urban Forestry for residential projects at (206) 684-TREE; for all others at (206) 684-5693 for approval of species and placement.

### **Alley Requirements** **Alley on North side**

Alley Grading: Standard alley cross section at established grade for portion of alley being improved. See Seattle Right of Way Improvements Manual (ROWIM) chapter 4. Apply for SDOT SIP Design Guidance. See SDOT CAM 2211.

Alley Drainage: Required for portion of alley being improved. A drainage review is required for any project which involves more than 750 sq ft of land disturbing activity in the public right-of-way. See Seattle Right of Way Improvements Manual (ROWIM) section 4.17.

Other requirements: Pave with concrete portion of alley to be dedicated.

## **SPU Requirements**



## Flow Control Compliance

All new, replaced, and disturbed topsoil shall be amended with organic matter per rules promulgated by the Director prior to completion of the project to improve onsite management of drainage water flow and water quality per SMC 22.805.020.E. For projects with 5,000 square feet or more of new and replaced impervious surface, a comprehensive drainage control plan shall be prepared by a licensed engineer.

All trail and sidewalk projects shall implement green stormwater infrastructure to the maximum extent feasible per SMC 22.805.030. Refer to DR SF-MEF and CAM 501. Table 4.6

## Water Availability

Your water availability assessment has been approved.

Water Availability Certificate reference number: 20131779

Water Availability Certificate status: Approved with No Changes

Prepared by: Clair LeFebre

## Existing Water System Information

Proximity of nearest fire hydrant is: 200 feet NW of property. Meets standards.

Water Main:

Size: 6 inches

Material: Cast Iron

Class: UNK

- Standard

- Abutting

Water Main is available to serve in: Boren Ave, Stewart St, Howell St

Distance of main to SW margin of street is 20 feet.

Public ROW width is 66 feet.

Water Service(s):

Size: 3/4"

Material: Copper

Size: 1"

Material: Copper

## Solid Waste

A Metro bus stop is fronting your property. An alternate location for pickup of your solid waste will be required. For questions about solid waste requirements, contact Liz Kain, (206) 684-4166, [Liz.Kain@seattle.gov](mailto:Liz.Kain@seattle.gov).

Your project is fronted by a major arterial. An alternate location for pickup of your solid waste is required. For questions about solid waste requirements, contact Liz Kain, (206) 684-4166, [Liz.Kain@seattle.gov](mailto:Liz.Kain@seattle.gov).

For all multifamily, commercial, and industrial properties, the requirements for solid waste storage and pickup are outlined in SPU CAM 1301, available on the web at:

[http://www.seattle.gov/util/stellent/groups/public/@spu/@csb/documents/webcontent/cos\\_004542.pdf](http://www.seattle.gov/util/stellent/groups/public/@spu/@csb/documents/webcontent/cos_004542.pdf). For

questions about solid waste requirements, contact Liz Kain, (206) 684-4166, [Liz.Kain@seattle.gov](mailto:Liz.Kain@seattle.gov).

## Other Requirements

Owners of residential property occupied by a tenant who will be displaced by housing demolition, substantial rehabilitation, change of use, or removal of use restrictions may need to obtain a Tenant Relocation License. Refer to DPD Tip 123, Seattle's Tenant Relocation Assistance Ordinance, for further information and instructions or call (206) 684-7979.

If your project involves additions or modification to or demolition of an existing building that contains four or more dwelling units or 4,000 square feet or more of non-residential area, and the building is a designated historic landmark or is 50 years old and meets the criteria set forth in SMC 25.12 for landmark designation, SEPA is required. Please contact the Department of Neighborhoods at (206) 684-0228 or [www.seattle.gov/neighborhoods/preservation](http://www.seattle.gov/neighborhoods/preservation) to determine if your building is a designated landmark or if a referral is necessary to determine if the building meets the criteria in SMC 25.12. Refer to Tip 208 for information regarding the application requirements for a SEPA review and Tip 3000 for information regarding landmarks and historic preservation.

If the scope of your proposed project changes before your DPD intake appointment or SDOT street improvement plan application, the requirements in this report may change. If there are municipal code and ordinance changes before our DPD intake appointment, the project must meet the new code requirements. Additional street improvement requirements may be triggered if a permit application for a development project on adjacent property is also undergoing review.

Please be aware that all persons or companies working within the City limits, including all contractors, subcontractors, permit expeditors and other service providers are required to possess a valid City of Seattle business license. This license is required in addition to any other licenses required by the State of Washington,

such as a contractors' license or state business license. For more information about City of Seattle business licenses, please contact inspector Michale Crooks at 206-684-8871, [Michale.Crooks@seattle.gov](mailto:Michale.Crooks@seattle.gov), or visit the [Licensing and Tax Administration Division website](#).